CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1288:164 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Gamewell, 12 Clintonville Rd, Northford, CT 06472

Contact: Brian Reynolds (203) 484-6124 FAX (203) 484-7309

DESIGN: Identiflex 602, Models IF 602-126 and IF 602-252 analog/addressable fire alarm control panel.

Local, auxiliary, remote station (reverse polarity), central station, releasing device, automatic, manual, waterflow and sprinkler supervisory services. Refer to the listee's data sheet for detailed

product description and operational considerations. System components:

IF-602 Main Board

UDACT 610 Digital Communicator

LP-864 Line Protector

SID Selenoid Interface Device RSM-95 Remote Solenoid Module

31057 Power Supply 31077 City Tie Card

31078 RS-232 Optical Isolator Module

31079 Analog/addressable loop Class "A" Card

31086 LCD Display Board

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances,

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally

compatible initiating and indicating devices. Refer to listee's Installation instructions

Manual for details.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required the control unit must be used with audible appliances

that can generate the temporal pattern signal.

NOTE: For <u>Fire Alarm Verification Feature</u> (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

04-22-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager